HIMACHAL PRADESH PUBLIC WORKS DEAPRTMENT

No. PWN/CB/WA/Misc. Building/2023-24/1322-23

Dated: 19/02/2024

不he Principal, M.K.M. Public School Bhadroya, Tehsil. Indora, Distt. Kangra (HP).

Subject: -

Application regarding requisite of Building Safety Certificate.

With reference to your office Letter No. & dated Nil, it is intimated that the School Building Safety Certificate of your School Building for the year 2024-25 has been prepared in this office and the same is being sent for information

DA/ Copy of Certificate.

utive Engineer,

Indora Division, HP.PWD.

Copy to the Assistant Engineer, Sub Division, HP.PWD. Indora for information w.r.t. his office Letter No. 773 dated 15.02.2024

> Executive Engineer, Indora Division, HP.PWD. Indora.

<u>CERTIFICATE</u>

The inspection of School building of Shri MKM Public School Bhadroya , Tehsil Indora Distt. Kangra (HP) has been conducted by the concerned Junior Engineer. On the basis of their inspection report, it has been found that no earthquake resistant norms have been adopted for the construction of School building. No structural drawing approved by the competent Govt. agency were produced by School authority. The structure of the building is a non-Engineering structure. Hence the structural safety of building can not be insured specially from earth quake point of view. This department will not be responsible for any type of loss of the life and property etc., if this structure fails under any circumstances. However as per visual inspection, the building appears to and accordingly, the Building Safety Certificate is being issued by this Department from 01.04.2024 to 31.03.2025. This Department could not access the structural safety of said building as the same was not constructed under the supervision of this Department.

Place:- Indora

Dated: - 09.02.2024

Junior\Engineer, Indora\Sub Division HP.PWD, Indora

Assistant Engineer, Indora Sub Division HP.PWD, Indora

Executive Engineer, Indora Division HP.PWD, Indora